

Engineering has reviewed the plans for the City Storage project submitted April 4, 2016 and have the following comments:

1. Please remove the Stormwater Management Plan "Approved" block from the drawing. The plan only needs the "Approved Plan – No Permit Required" block on it.
2. Although this project does not require a permit (<2,500sf newly constructed impervious surface), please quantify on the plans, the amount and breakdown of existing on-site impervious surface area (buildings, sidewalks, other, etc.), of on-site and off-site impervious to be demolished/removed and of on-site and off-site newly constructed impervious surface area.